




019-120-66-021/022

NETRACK
WALL - MOUNTED CABINET RACK 19"
F - LINE

12U/600x600mm - GLASS DOOR


019-120-66-021/022



- 1. GLASS FRONT DOOR
- 2. VENTILATION HOLES
- 3. FRONT DOOR LOCK

FRONT ELEVATION


019-120-66-021/022



- 1. SIDE PANEL
- 2. VENTILATION HOLES
- 3. SIDE PANEL LOCK INSTALLATION SPACE
- 4. LATCH FOR SIDE PANEL

RIGHT SIDE ELEVATION


019-120-66-021/022



- 1. STEEL REAR PANEL
- 2. HOLES FOR HANGING

REAR ELEVATION


019-120-66-021/022



- 1. SIDE PANEL
- 2. VENTILATION HOLES
- 3. SIDE PANEL LOCK INSTALLATION SPACE
- 4. LATCH FOR SIDE PANEL

LEFT SIDE ELEVATION


019-120-66-021/022



- 1. VENTILATION HOLES
- 2. TOP BACK CABLE ENTRY
- 3. HOLE FOR FAN UNIT INSTALLATION

TOP ELEVATION


019-120-66-021/022



- 1. VENTILATION HOLES
- 2. BOTTOM BACK CABLE ENTRY

BOTTOM ELEVATION

019-120-66-021/022




- 1. GLASS FRONT DOOR
- 2. VENTILATION HOLES
- 3. TOP BACK CABLE ENTRY
- 4. ANGLE MOUNTING BRACKET BAR
- 5. MOUNTING SPARE RACK PROFILE
- 6. SIDE PANEL
- 7. STEEL REAR PANEL
- 8. HOLE FOR FAN UNIT INSTALLATION (105X105mm)

RACK DISTANCES

A	min.	-	50mm
B	max.	-	476mm
C	min.	-	66mm

SECTION A-A
- TOP COVER VIEW

019-120-66-021/022




- 1. GLASS FRONT DOOR
- 2. BOTTOM BACK CABLE ENTRY
- 3. ANGLE MOUNTING BRACKET BAR
- 4. MOUNTING SPARE RACK PROFILE
- 5. SIDE PANEL
- 6. STEEL REAR PANEL

RACK DISTANCES

A	min.	-	50mm
B	max.	-	476mm
C	min.	-	66mm

SECTION B-B
-BOTTOM PANEL VIEW


019-120-66-021/022



- 1. VENTILATION HOLES
- 2. ANGLE MOUNTING BRACKET BAR
- 3. MOUNTING SPARE RACK PROFILE
- 4. SIDE PANEL
- 5. STEEL REAR PANEL

SECTION C-C

019-120-66-021/022



- 1. GLASS FRONT DOOR
- 2. VENTILATION HOLES
- 3. TOP/BOTTOM BACK CABLE ENTRY
- 4. ANGLE MOUNTING BRACKET BAR
- 5. MOUNTING SPARE RACK PROFILE
- 6. SIDE PANEL
- 7. STEEL REAR PANEL
- 8. SIDE PANEL LOCK INSTALLATION SPACE

RACK DISTANCES

A	min.	-	50mm
B	max.	-	476mm
C	min.	-	66mm

SECTION D-D